



Analytical Results

Sub-Matrix: WATER (Matrix: WATER)				Sample ID	Head Of Works Head of Works	#1 RWDT	#2 License Discharge	----	----
Sampling date / time				06-Jun-2023 08:15	06-Jun-2023 08:10	06-Jun-2023 08:00	----	----	
Compound	CAS Number	LOR	Unit	CA2303544-001	CA2303544-002	CA2303544-003	-----	-----	
				Result	Result	Result	----	----	
EA005CA: pH									
pH	----	0.01	pH Unit	----	----	7.38	----	----	
EA025CA: Suspended Solids									
Suspended Solids (SS)	----	2	mg/L	----	<2	<2	----	----	
EP020CA: Oil and Grease									
Oil and Grease	----	1	mg/L	----	<1	<1	----	----	
EP030CA: Biochemical Oxygen Demand									
Biochemical Oxygen Demand	----	2	mg/L	107	<2	<2	----	----	
EK055CA: Ammonia as N									
Ammonia as N	7664-41-7	0.1	mg/L N	----	<0.1	<0.1	----	----	
EK062CA: Total Nitrogen as N									
Total Nitrogen as N	----	0.05	mg/L N	----	----	4.94	----	----	
EK067CA: Total Phosphorus as P									
Total Phosphorus as P	----	0.01	mg/L P	----	----	0.01	----	----	
MW006CA: Faecal coliforms and E. coli by MF									
Thermotolerant Faecal Coliforms (Presumptive)	----	1	CFU/100mL	----	<1	2	----	----	
Thermotolerant Faecal Coliforms (Confirmed)	----	1	CFU/100mL	----	<1	2	----	----	
E. coli (Confirmed)	----	1	CFU/100mL	----	<1	1	----	----	