



Sub-matrix: WATER (Matrix: WATER)				Sample ID	#1	#2	----	----	----
				RWDT	Licence Discharge				
Sampling date / time				17-Jan-2023 07:25	17-Jan-2023 07:20	----	----	----	
Compound	CAS Number	LOR	Unit	CA2300355-001	CA2300355-002	-----	-----	-----	
				Result	Result	----	----	----	
EA005CA: pH									
pH		0.01	pH Unit	----	7.55	----	----	----	
EA025CA: Suspended Solids									
Suspended Solids (SS)		2	mg/L	<2	3	----	----	----	
Oil and Grease		1	mg/L	<1	<1	----	----	----	
EP030CA: Biochemical Oxygen Demand									
Biochemical Oxygen Demand		2	mg/L	<2	<2	----	----	----	
EK055CA: Ammonia as N									
Ammonia as N	7664-41-7	0.1	mg/L N	<0.1	<0.1	----	----	----	
EK062CA: Total Nitrogen as N									
Total Nitrogen as N		0.05	mg/L N	----	1.73	----	----	----	
EK067CA: Total Phosphorus as P									
Total Phosphorus as P		0.01	mg/L P	----	0.04	----	----	----	
MW006CA: Thermotolerant Faecal Coliforms by MF									
Thermotolerant Faecal Coliforms (Presumptive)		1	CFU/100mL	<1	8	----	----	----	
Thermotolerant Faecal Coliforms (Confirmed)		1	CFU/100mL	<1	8	----	----	----	