

ANALYTICAL RESULTS

Client Sample ID		HEAD OF WORKS	#1 RWDT	#2 LICENCE DISCH					
Sampled Date		03/06/2025 08:00:00 AM	03/06/2025 08:10:00 AM	03/06/2025 08:00:00 AM					
Sample Number		L25049884	L25049885	L25049886					
CHEMISTRY									
WC17NS : Biochemical oxygen demand									
BOD5	mg/L	120	6	<2					
Date of Performance	DD/MM/YY	04/06/25	04/06/25	04/06/25					
WC26NS500 : Oil & Grease									
Oil & Grease	mg/L	-	<5	<5					
Date of Performance	DD/MM/YY		04/06/25	04/06/25					
WC34MET : pH in Water									
pH	pH units	-	-	7.3					
Date of Performance	DD/MM/YY			04/06/25					
WC44NS : Total, Fixed & Volatile Suspended Solids									
Total Suspended Solids	mg/L	-	<2	6					
Date of Performance	DD/MM/YY		05/06/25	08/06/25					

"-" = Not required or refer to Laboratory comment

Client Sample ID		HEAD OF WORKS	#1 RWDT	#2 LICENCE DISCH					
Sampled Date		03/06/2025 08:00:00 AM	03/06/2025 08:10:00 AM	03/06/2025 08:00:00 AM					
Sample Number		L25049884	L25049885	L25049886					
MICRO									
MI28 : Total Coliforms and/or E.coli by Enzyme Substrate Method									
Total Coliforms	Orgs / 100mL	-	<1	68					
E.coli	Orgs / 100mL	-	<1	12					
Date of Performance	D/M/Y H:M		04/06/25 09:05	04/06/25 09:05					
NUTRIENTS									
NU102 : Total Nitrogen & Total Phosphorus									
Total Nitrogen	mg/L	-	-	2.64					
Total Phosphorus	mg/L	-	-	0.085					
Date of Performance	DD/MM/YY			04/06/25					
NU40 : Ammonia - Nitrogen									
Ammonia NH3 -N Low Level	mg/L	-	<0.01	0.01					
Date of Performance	DD/MM/YY		04/06/25	04/06/25					

"-" = Not required or refer to Laboratory comment